

11. PERMITTEE SHALL OPERATE THE PUMP SCHEDULE IN ACCORDANCE WITH THE FOLLOWING SCHEDULE:

PUMP STATION NO. 1:		PUMP OPERATION (NSID STAGES)		DISCHARGE TO (L-36 STAGES)	
NO.	CAPACITY	ON	OFF	L-36	WCA-2A
1	50000 GPM	> 7.7	7.0	AND < 11.4	
		> 7.7	7.0	AND	> 11.4
2	50000 GPM	> 7.85	< 7.7	AND	> 11.4
3	50000 GPM	> 7.85	< 7.7	AND	> 11.4
4	50000 GPM	> 7.85	< 7.7	AND	> 11.4

PUMP STATION NO. 2		PUMP OPERATION (NSID STAGE)		PUMP OPERATION (L-36 STAGE)	
NO.	CAPACITY	ON	OFF	OFF	
1	50000 GPM	7.85	< 7.7	OR	> 11.4
2	50000 GPM	8.00	< 7.7	OR	> 11.4
3	50000 GPM			STANDBY PUMP	

NOTE: STAGES IN THE L-36 CANAL WILL BE DETERMINED BY A GAGE IMMEDIATELY DOWNSTREAM OF PUMP STATION NO. 2